

**PRASAR BHARATI  
(BROADCASTING CORPORATION OF INDIA)  
OFFICE OF THE ADDITIONAL DIRECTOR GENERAL[E] (SOUTH ZONE)  
ALL INDIA RADIO & TELEVISION  
SWAMI SIVANANDA SALAI,CHENNAI-600 005.**

File No. CESZ/PUR-II/PSEA/NIT-01/2011-12/

Date:- 02.08.2011.

**CORRIGENDUM**

**Sub:- SITC OF 6 PANEL & 4 PANEL HT SWITCH GEAR -Specification No.  
XPS 12/2010, XPS 16/2011 & XPS-15/2011.**

**Ref: This Office Tender No. CESZ/PUR-II/PSEA/NIT-01/2011-12  
dt. 13.07.2011.**

| Sl. No.  | Specifications No. & Item No.  | FOR  | READ AS   |
|----------|--|--|---|
| 1        | <b>XPS 12/2010, XPS 16/2011 &amp; XPS-15/2011</b> Sec-II Design feature of the equipment 2.5.5                           | Vacuum loss indicator lamp wire for alarm shall be provided for all breaker panels.                | Method to indicate vacuum loss may be notified                                    |
| 2        | <b>XPS 12/2010, XPS 16/2011 &amp; XPS-15/2011</b> Sec-II Design feature of the equipment 2.7 Potential Transformer 2.7.1 | Potential Transformers (PT) 11000/112V/ 3 phases, Oil filled complete (draw out type)              | Potential Transformers (PT) 11000/112V/ 3 phases, Epoxy cost resin(draw out type) |
| 3        | <b>XPS 12/2010, XPS 16/2011 &amp; XPS-15/2011</b> Sec-III Technical Specification 3.2.1 HT Switch gear(j)                | Thickness of MS Sheet used for the board. (3.0 mm).  | Thickness of MS Sheet used for the board. (2.5 mm).                               |
| 4<br>(a) | <b>XPS 12/2010, XPS 16/2011 &amp; XPS-15/2011</b> Sec-III Technical Specification 3.2.2 vacuum circuit breakers (m)      | Number of tanks.   | May be deleted  |
| (b)      | (n)  | Steady hydraulic test pressure that tanks with stand for one minute without permanent deformation. | May be deleted  |

**The tender opening (Technical bid) has been Re-Scheduled  
on 11.08.2011.**

Yours faithfully,



(T. SHANMUGARAJU)  
DEPUTY DIRECTOR (ENGG)(PURCHASE)  
FOR ADDITIONAL DIRECTOR GENERAL [E] (S.Z)